




The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner

LETTER OF DEFICIENCY

No. WD SS 05-05

April 5, 2005

Ms. Jennifer McDonald
1053 New Hampshire Route 4A
Enfield, NH 03748

RE: Failed Septic System, Lot 16, Map 39, Enfield

Dear Ms. McDonald:

On April 1, 2005, personnel from the Town of Enfield forwarded information to the Department of Environmental Services, Water Division ("DES") relative to an inspection conducted of the above-referenced property, described as Lot # 16, on Tax Map # 39, and located on Route 4A, Enfield, NH, 03748 ("the Property"). The purpose of this inspection was to determine whether you were in compliance with RSA 485-A and its implementing regulations, the Subdivision and Individual Sewage Disposal System Design Rules, Env-Ws 1000 ("the Rules").

As a result of the inspection, the following deficiency was noted:

1. Septage visible on the ground surface above the leach field indicates that the leach field is in failure.

DES expects the above deficiency to be permanently corrected within 90 days by initiating and completing the following measures:

1. Engage a permitted septic system designer to prepare and submit septic system plans and specifications to DES for the total waste load generated on the Property.
2. Obtain approval to construct the system.
3. Construct and obtain approval to cover and use the system.
4. Operate and maintain the system in accordance with NH Administrative Rule Env-Ws 1023.

During interim between receipt of this letter and the date by which permanent corrections have been completed, as an alternate to vacating the premises, DES expects

that collected sewage will be pumped and disposed in accordance with NH Administrative Rule Env-Ws 1600 at sufficient frequent intervals to prevent further overflow. If this alternative is utilized, it is advised that pumping receipts be retained.

DES believes the cited deficiencies will be corrected within 90 days and a report describing the corrective measures can be submitted to this office within 90 days of receipt of this letter.

In the event compliance is not achieved within this period, DES may take further action against you, including issuing an order requiring the above items to be corrected, initiating an administrative fine proceeding, and/or referring the matter to the New Hampshire Department of Justice for imposition of civil and/or criminal penalties. In addition, DES personnel will reinspect the Property at a later date to determine whether you have come into, and are maintaining, full compliance with all applicable statutes and directives.

The written report as requested above should be addressed as follows:

Richard J. de Seve, SSB, DES
Department of Environmental Services
6 Hazen Drive, PO Box 95
Concord, NH 03302-0095

Your prompt cooperation is appreciated. Should you have any questions regarding this letter, please contact Richard J. de Seve at 271-3442.

Sincerely,

COPY


William E. Evans, P.E.
Administrator
Subsurface Systems Bureau

WEE/RJD

CERTIFIED MAIL 7099 3400 0002 9772 8274

Cc: James G. Falicon, SSB, DES

Gretchen C. Hamel, Enforcement Coordinator, DES ✓

Board of Selectmen, Town of Enfield

P. Niely, Health Officer, Town of Enfield

Richard J. de Seve, SSB, DES